

Copy of the Fire Safety Certificate issued by Fire Safety Officer



rfo-sfps-rajkot@gujarat.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2023/00041724

Date: 13/09/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2023/00041724/R1

Building Occupancy/Category: Educational (non-residential)

To,

Vinod Khandivad
LAJAI CHOWKDI MORBI – RAJKOT HIGHWAY LAJAI MORBI MORBI Morbi 363641
Fire Region: Rajkot RFO
Mobile No: 9825684680 Email ID: gvschoolac@gmail.com

This has reference to your Application No. **2024/00085490** dated 13/09/2024 for **Fire Safety Certificate Renewal (FSCR)** for the building/premise **GREEN VALLEY INTERNATIONAL SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: MORBI
5. Name of Block(s): GREEN VALLEY INTERNATIONAL SCHOOL

The building/premise was inspected on **13/09/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **13/09/2024**
2. Six monthly inspection was done on **13/09/2024**

The Fire Safety Certificate is renewed for a period of **two (2) years** upto **13/09/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Jignesh Pravinchandra Joshi
Fire Safety Officer - Specialist (FSO-S)
2021/000257

Date: 13/09/2024
Time: 02:06 PM



FSCA/O/RFORAJ/2023/00041724/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

Tanay Chukea
Principal
Green Valley International School
Lajai Chowkdi, Ta. Tankara (Morbi)

Shree Archnam Education Trust
Pravin
Trusty / Authorised Signatory